

**MONTANA-DAKOTA UTILITIES CO.
ANNUAL ELECTRIC RELIABILITY REPORT-MONTANA
CALENDAR YEAR 2005
MONTANA RULE 38.5.8619**

	Montana	Glendive District	Wolf Point District
Reliability Index with Identified Storm Event 1/			
SAIFI (System Average Interruption Frequency Index)	0.502	0.664	0.058
SAIDI (System Average Interruption Duration Index)	56.180	65.420	30.850
CAIDI (Customer Average Interruption Duration Index)	111.950	98.530	535.640

	Montana	Glendive District	Wolf Point District
Reliability Index-Without Identified Storm Event 1/			
SAIFI (System Average Interruption Frequency Index)	0.497	0.664	0.039
SAIDI (System Average Interruption Duration Index)	49.870	65.420	7.226
CAIDI (Customer Average Interruption Duration Index)	100.386	98.530	187.640

SAIDI and CAIDI reported in minutes

1/ A storm occurring in Brockton, Montana (Wolf Point District) on July 11, 2005 while not classified as a major storm event by definition did affect reliability indices.